## **Autonics**

# **TEMPERATURE CONTROLLER** TOS SERIES





Thank you very much for selecting Autonics products. For your safety, please read the following before using.

## Caution for your safety

are not followed.

\*Please keep these instructions and review them before using this unit.

\*Please observe the cautions that follow;

**Marning** Serious injury may result if instructions are not followed. ⚠ Caution Product may be damaged, or injury may result if instructions

\*The following is an explanation of the symbols used in the operation manual. ▲ caution: Injury or danger may occur under special conditions.

#### **Marning**

- 1. In case of using this unit with machineries(Nuclear power control, medical equipment, vehicle, train, airplane, combustion apparatus. entertainment or safety device etc), it requires installing fail-safe device, or contact us for information on type required.
- It may result in serious damage, fire or human injury.
- 2. This unit must be mounted on panel. It may give an electric shock
- 3. Do not repair or checkup when power on.
- It may give an electric shock
- 4. Do not disassemble and modify this unit, when it requires. If needs, please contact us.


It may give an electric shock and cause a fire.


#### **⚠** Caution

- 1. This unit shall not be used outdoors.
- It might shorten the life cycle of the product or give an electric shock
- 2. When wire connection, No.20AWG(0.50mm<sup>2</sup>) should be used and screw bolt on terminal block with 0.74N · m to 0.90N · m strength. It may result in malfunction or fire due to contact failure.
- 3. Please observe specification rating.
- t might shorten the life cycle of the product and cause a fire
- 4. Do not use the load beyond rated switching capacity of Relay contact. It may cause insulation failure, contact melt, contact failure, relay broken
- 5. In cleaning the unit, do not use water or an oil-based detergent. t might cause an electric shock or fire that will result in damage to the product.
- 6. Do not use this unit at place where there are flammable or explosive gas, humidity, direct ray of the sun, radiant heat, vibration, impact etc. It may cause a fire or explosion
- 7. Do not inflow dust or wire dregs into inside of this unit.
- t may cause a fire or mechanical trouble
- 8. Please wire properly after checking the polarity of terminals when connect thermocouples.

It may cause a fire or explosion


#### Dimensions





\*The above specification are changeable without notice anytime.


### Ordering information



## Specifications


Model		103	П
Power supply		100-240VAC 50/60Hz	11
Allowable voltage range		90 to 110% of rated voltage	
Power consumption		2.2VA	]
Display method		Non-display	] [
Setting method		Dial setting	] [
Setting accuracy		F • S ±2%	]]]
Sensor input		Thermocouples : K(CA), J(IC) / RTD : Pt100Ω	∐ '
Input line resistance		Thermocouples: Max. 100Ω, RTD: Max. 5Ω per a wire	Ш
Con Pro	/OFF control	Hysteresis: F⋅S 0.5 to ±0.2% Fixed□	Ш
	portional ntrol	-Proportional band : F • S 3% ±0.5% Fixed -Period : 20sec. ±5sec. fixed□	
Control output		Relay contact output:250VAC 2A 1c SSR Output:12VDC ±3V Load 20mA max.	
Self-diagnosis		Built-in burn out function	11
Insulation resistance		Min. 100MΩ(at 500VDC)	11
Dielectric strength		2000VAC 50/60Hz for 1 minute	] [
Noise strength		$\pm 2 kV$ the square wave noise(pulse width:1 $\mu s)$ by the noise simulator	
Vibration	Mechanical	0.75mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 1 hour	
	Malfunction	0.5mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 10 minutes	
Shock	Mechanical	300m/s <sup>2</sup> (Approx. 30G) 3 times at X, Y, Z direction	11
	Malfunction	100m/s² (Approx. 10G) 3 times at X, Y, Z direction	] [ ]
Relay life cycle	Mechanical	Min.10,000,000 times	] [
	Electrical	Min.100,000 times(250VAC 2A resistive load)	Ш
Ambient temperature		-10 to 50℃(at non-freezing status)	Ш
Storage temperature		-25 to 65℃(at non-freezing status)□	П
Ambient humidity		35 to 85%RH	П
Weight		Approx. 104g	П
Approval		File No:E164579	П

## Connections



## ON/OFF control


The drawing shows that the output turns on when the temperature is lower than the set value. (Heater ON) The output turns off when temperature is equal or higher than the set value. (Heater OFF)



As like above picture, the control value is up and down by set value, it is called Hunting. And Overshoot is occurred at initial point when just power on. If the Hunting and Overshoot is less, it will be a good


## Hysteresis

The ON/OFF control has hysteresis due to reduce the chattering or noise affection. Generally make hysteresis bigger for compressor of cooler due to this reason.



Ex)If temperature range is 0 to  $400^{\circ}$ C and hysteresis is  $0.5\%(2^{\circ}$ C), therefore when the set value is 300°C, 301°C:OFF and 299°C:ON.

## Proportional control



\*If the temperature is getting higher, ON time will be shorter.

Pulse output type of ON/OFF such as Relay output or SSR output (Voltage output) are ON/OFF repeatedly with constant cycle. When the PV and SV is the same, the output value will be 50% and ON/OFF time rate is 1:1

## ■ How to select ON/OFF or Proportional by plug pin

Control mode selection by plug pin




\* P : Proportional control \* F : ON/OFF control

#### Function


- ●BURN OUT detection function:
- Make the output OFF when the thermocouple is broken.
- The output is 24VDC  $\pm$ 3V 20mA max for driving external SSR.
- •Direct/Reverse operation: Reverse operation is the output ON when the display value is lower than set value, Direct operation is for cooler. \*This product operates as reverse operation.

#### Load connection

## •SSR output



#### ●Relay output



## Applications

Food	Packaging machinery, Banding machinery	
Plastic	Plastic machinery, Film making system, etc.	
Industry	Electric furnace, Auto soldering machine, Drying machine, etc.	
Textile□	Body press, Textile machine, Sizing machine	
Etc.0	Cement making machinery	

## Caution for using

- 1. Installation environment
- 1 It shall be used indoor
- ②Altitude Max. 2000m
- ③Pollution Degree 2
- 4 Installation Category II
- 2. Please use separated line from high voltage line or power line in order to avoid inductive noise.
- . Please install power switch or circuit-breaker in order to cut power supply off.
- 4. The switch or circuit-breaker should be installed near by users.
- 5. Do not use this product as Volt-meter or Ampere-meter, this is a temperature controller
- 6. Be sure to use compensating wire when extends wire from controller, otherwise the temperature deviation will be occurred at the part where wires
- are connected each other 7. In case of using RTD sensor, 3wire type must be used.
- If it needs to extend the line, 3wires must be used with the same thickness
- as the line. It might cause the deviation of temperature if the resistance of line is different.
- 8. In case of making power line and input signal line close, line filter for noise protection should be installed at power line and input signal line should be 9. Keep away from the high frequency instruments. (High frequency welding
- machine & sewing machine, big capacitive SCR controller) 10. When change the control mode, please apply power after change the
- mode switch. 11. Do not connect power line on No.1, 2, 3 of terminal block for the sensor.
- \*It may cause malfunction if above instructions are not followed.

## Main products

- COUNTER
- TEMPERATURE CONTROLLER ■ PANEL METER
- TACHOMETER/ LINE SPEED METER/
- PULSE METER ■ DISPLAY UNIT
- PROXIMITY SENSOR
- PHOTOELECTRIC SENSOR FIBER OPTIC SENSOR
- PRESSURE SENSOR
- ROTARY ENCODER
- SENSOR CONTROLLER ■ POWER CONTROLLER
- STEPPING MOTOR & DRIVER
- & CONTROLLER

## AUTONICS Corporation http://www.autonics.net

41-5, Yongdang-ri, Ungsang-eup, Yangsan-si Gyeongnam, Korea 626-847

- INTERNATIONAL SALES :
- 512 Ansung B/D, 410-13, Shindorim-dona. Guro-gu, Seoul, Korea 152-070
- TEL:82-2-2679-6585 / FAX:82-2-2679-6556 ■ E-mail: sales@autonics.net

NO20030117-EP-KE-03-0080E